

DOOR COUNTY PRIVATE WELL MONITORING PROGRAM TEST RESULT

Water Quality Standards (Level Detected)	Fall 2024	Spring 2024	Fall 2023	Spring 2023	Fall 2022	Spring 2022	2021	2020	2019	Wisconsin Average
<i>Total Wells Tested</i>	182	224	162	195	196	260	217	295	148	
Total Coliform (0 MPN/100 ml)	88%	96%	88%	95%	92%	90%	76%	86%	84%	
Total Coliform (1-10 MPN/100 ml)	9%	2%	6%	5%	6%	6%	14%	9%	10%	17%
Total Coliform (10-100 MPN/100 ml)	2%	1%	4%	0%	2%	3%	6%	3%	4%	(>0 MPN/ 100 ml)
Total Coliform (>100 MPN/100 ml)	1%	0%	2%	1%	1%	1%	3%	1%	1%	
E.coli (0 MPN/100 ml)	100%	99%	98%	100%	100%	99%	98%	99%	100%	
E.coli (1-10 MPN/100 ml)	0%	0%	1%	0%	0%	<1%	1%	1%	0%	5%
E.coli (10-100 MPN/100 ml)	0%	0%	1%	0%	0%	0%	<1%	0%	0%	(>0 MPN/ 100 ml)
E.coli (>100 MPN/100 ml)	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Nitrate (0 mg/L)	76%	69%	72%	74%	74%	80%	75%	72%	71%	
Nitrate (2-5 mg/L)	17%	23%	18%	18%	18%	16%	11%	16%	16%	8%
Nitrate (5-10 mg/L)	7%	8%	8%	7%	7%	4%	12%	12%	11%	(>10 mg/L)
Nitrate (>10 mg/L)	1%	0%	2%	1%	1%	0%	2%	<1%	2%	
Arsenic (<2 µg/L)	89%	91%	91%	92%	92%	88%	89%	90%	99%	
Arsenic (2-5 µg/L)	11%	7%	5%	7%	7%	11%	9%	6%	1%	5%
Arsenic (5-10 µg/L)	1%	2%	4%	1%	1%	1%	1%	3%	0%	(>10 µg/L)
Arsenic (>10 µg/L)	0%	0%	0%	0%	0%	0%	1%	<1%	0%	